



BW ELECTRIC
 13841 Malabar Ave
 White Rock BC V4B 2X8
 604-765-4591
www.bwelectric.ca

Heat Trace Report

Job Number	3301
Wire Type	Raychem

General Contractor	CPM
Address	19945 Brydon Cres. Langley
Building Name	The Atrium
Permit Number	EL-1385476-2022

Run #	Pipe Type (Sprinkler / Domestic)	Pipe Type	Location	Capitance (nF)	Length (Feet)	Watts	Breaker Size	Megger Tests (GΩ)			Control	Pass
								500v DC	1000v DC	2500v DC		
1	Sprinkler	Steel	P1	16.8	114.2	571.2	2P 15A	5.5	5.5	22.0	465	Yes
2	Sprinkler	Steel	P1	4.8	32.6	163.2		5.5	5.5	22.0		Yes
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												

** GFI BREAKER

Notes

1 -
2 -
3 -

Tested by	Brian Wuttke
Date	May 31, 2022
Job Number	3301
Signature	