



Certificate No:PS112693130
File No: S24896 CCN: DAYIC
Service Center No: 1
Expires: 09/29/2027
Issued: 09/29/2022

FIRE PROTECTIVE SIGNALING CERTIFICATE (CAN/ULC-S561)

This Certifies that the Alarm Companies whose names appear below are Listed by ULC and are authorized to install, monitor, and maintain Protective Signaling Fire Alarm Systems in compliance with the requirements in CAN/ULC-S561 for Protective Signaling Systems.

The assignment of responsibilities as indicated shall be set out in a contract between the companies involved.

The Alarm Monitoring Company named on this certificate bears the responsibility for the monitoring of the status of signals generated by the system and for the keeping of records respecting these activities.

The Alarm Installation Company named on this certificate bears the responsibility for the correctness of the system installation, periodic testing, maintenance repair, as well as the keeping of records respecting these activities.

It is also the responsibility of the Alarm Installation Company to confirm that the equipment used in the installation is ULC Labeled and is suitable for the application. All required service is provided for in the care contract between the Alarm Installation Company and the Occupant.

ULC makes no representations or warranties, expressed or implied, that the alarm system will prevent any loss by fire, smoke, water damage, or otherwise, or that the system will in all cases provide the protection for which it is installed or intended. The certificate is evidence that the signaling devices are monitored by a ULC Listed Alarm Monitoring Company and that the installation, maintenance and service is provided by a ULC Listed Alarm Installation Company, which are subject to countercheck field inspections by ULC Representatives. This certificate is to be posted at the Subscriber's site and is valid only with a current maintenance contract.

ULC is not an insurer and does not assume any obligation or undertake to discharge any liability of the Alarm Companies or any other party for any loss, which may result from failure of equipment, incorrect installation, non-conformity with requirements, cancellation of this certificate or withdrawal of the Alarm Company from Listing by ULC prior to the expiration date appearing on this certificate.

SN: PS112693130

Protected Property:

ATRIUM MONITORING
19945 BRYDON CRESCENT
LANGLEY, BC V3A 1J6

Alarm Service Company:

VANCOUVER FIRE & SECURITY, DIV
OF
0777792 BC LTD
22131 FRASERWOOD WAY
RICHMOND
BC V6W 1J5 CANADA

Alarm System Description: This system is installed and operated in accordance with STANDARD CAN/ULC-S561,2020 edition.

System Number: XJ3528

System Type: Fire Protective Signaling Authority Having Jurisdiction: CITY OF LANGLEY

Responding Fire Department: LANGLEY FIRE DEPARTMENT

System Deviations from Referenced Standards: None

System Type: Fire Panel

Alarm Transmission Method: Digital Dialler

Local F/A Interconnection: Yes

Line Security: Passive

Control or Transmitter Unit: DSC HS2016,,TL280